



Product Service

Attestation of Conformity

No. N8A 108560 0002 Rev. 02

Holder of Certificate: **Ningbo Victor Solar Technology Co., Ltd.**
No. 555, Rixian Road, Binhai Economic Development Zone
315300 Cixi City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062019501-02

Date, 2021-08-03

(Zhulin Zhang)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 108560 0002 Rev. 02

Model(s):

VSMH144-xxx-M6 (xxx=425-445, in step of 5);
 VSMH120-xxx-M6 (xxx=355-370, in step of 5);
 VSMH96-xxx-M6 (xxx=285-295, in step of 5);
 VSMH72-xxx-M6 (xxx=215-220, in step of 5);
 VSMH60-xxx-M6 (xxx=180-185, in step of 5);
 VSMH52-xxx-M6 (xxx=155-160, in step of 5);
 VSMH44-xxx-M6 (xxx=130-135, in step of 5);
 VSMH36-xxx-M6 (xxx=105-110, in step of 5);
 VSMH32-95-M6, VSMH32-80-M6, VSMH36-70-M6,
 VSMH32-60-M6, VSMH36-50-M6, VSMH32-40-M6,
 VSMH36-30-M6, VSMH32-20-M6, VSMH32-10-M6;
 VSM72-xxx-G1 (xxx=375-405, in step of 5);
 VSM60-xxx-G1 (xxx=315-335, in step of 5);
 VSM54-xxx-G1 (xxx=285-300, in step of 5);
 VSM48-xxx-G1 (xxx=250-270, in step of 5);
 VSM36-xxx-G1 (xxx=190-200, in step of 5);
 VSM32-xxx-G1 (xxx=155-180, in step of 5);
 VSMH144-xxx-G1 (xxx=375-410, in step of 5);
 VSMH120-xxx-G1 (xxx=315-340, in step of 5);
 VSMH32-xxx-G1 (xxx=130-150, in step of 5);
 VSMH32-110-G1, VSMH32-120-G1;
 VSMH36-xxx-G1 (xxx=100-105, in step of 5);
 VSMH32-xx-G1 (xx=65-95, in step of 5);
 VSMH36-60-G1, VSMH36-55-G1, VSMH32-50-G1,
 VSMH32-45-G1, VSMH36-40-G1, VSMH36-35-G1,
 VSMH34-30-G1, VSMH34-25-G1, VSMH36-20-G1,
 VSMH36-15-G1, VSMH36-10-G1.
 VSMH144-xxx-M10 (xxx=525-555, in step of 5);
 VSMH120-xxx-M10 (xxx=440-460, in step of 5);
 VSMH108-xxx-M10 (xxx=395-410, in step of 5);
 VSMH96-xxx-M10 (xxx=350-370, in step of 5);
 VSMH84-315-M10, VSMH84-320-M10;
 VSMH72-xxx-M10 (xxx=265-275, in step of 5);
 VSMH60-xxx-M10 (xxx=220-230, in step of 5);
 VSMH56-205-M10, VSMH56-210-M10;
 VSMH52-190-M10, VSMH52-195-M10;
 VSMH48-xxx-M10 (xxx=175-185, in step of 5);
 VSMH44-xxx-M10 (xxx=160-165, in step of 5);
 VSMH36-130-M10, VSMH36-135-M10; VSMH33-120-M10.
 VSMH36-xx-M10 (xx=10-90, in step of 10).
 xxx is standing for rated output power at STC.



Product Service

Attestation of Conformity

No. N8A 108560 0002 Rev. 02

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, P.R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06